



GLOBAL TECH. ENVIRO EXPERTS PVT. LTD.
(FORMERLY GLOBAL EXPERTS)
An ISO-9001:2008 Certified Company

C-23, BJB Nagar,
Bhubaneswar-751014
Ph.: 0674-2436853
Fax:- 0674-2433487
E-mail- globalexerts@rediffmail.com
globalexerts@gmail.com
consult@globalexerts.in
visit us: www.globalexerts.in

STACK MONITORING RESULT

Name of Industry & Address	:	M/s SHIVA CEMENT LIMITED Teleghana, Kutra, Sundargarh
Stack Pattern	:	Circular
Date of Monitoring	:	26-10-15
Date of Analysis	:	28-10-15
Reference No.	:	Stk-36/ 15

Sl. No.	Parameters	(Result)				Protocols
		Cement Mill	Kiln	Coal Mill	Raw Material Mill	
1	Particulate Matter (PM) in mg/Nm ³ .	79.4	70.7	74.3	71.2	IS:11255 (Pt 1)
2	Flue Gas Temperature (°C) T _s	32.1	105.6	31.8	31.6	IS:11255 (Pt 3)
3	Flue Gas Velocity (m/s)	4.4	5.6	4.7	4.8	IS:11255 (Pt 3)
4	Ambient Temperature (T _a)	31.1	31.8	30.9	30.5	-
5	Height of H ₂ O Column in mm	1.67	2.18	1.94	2.03	-
6	Carbon Monoxide (CO) in ppm	-	132	-	-	IS:13270/GC
7	Carbon Dioxide (CO ₂) in %	-	10.5	-	-	IS:13270/GC
8	Oxygen (O ₂) in %	-	10.4	-	-	Orsat Apparatus
9	Sulfur Dioxide (SO ₂) in ppm	-	29	-	-	IS:11255 (Pt 2)
10	Oxides of Nitrogen (NO _x) in ppm	-	46	-	-	IS:11255 (Pt 7)

Sampling Instrument : Stack Monitoring Kit VSS-I & Flue Gas Analyzer (Quintox)

Permissible Standard for PM: 150 mg/ Nm³.

For Global Tech Enviro Experts Pvt. Ltd.


(Authorised Signatory)