



GLOBAL TECH. ENVIRO EXPERTS PVT. LTD.

(FORMERLY GLOBAL EXPERTS)

An ISO-9001:2008 Certified Company

C-23, BJB Nagar.

Bhubaneswar-751014

Ph.: 0674-2436853

Fax:- 0674-2433487

E-mail-

globalexerts@rediffmail.com

global.experts@gmail.com

consult@globalexerts.in

visit us

www.globalexerts.in

STACK MONITORING RESULT

Name of Industry & Address	:	M/s SHIVA CEMENT LIMITED Teleghana, Kutra, Sundargarh
Stack Pattern	:	Circular
Date of Monitoring	:	30-07-15
Date of Analysis	:	01-08-15
Reference No.	:	Stk-22/ 15

Sl. No.	Parameters	(Result)				Protocols
		Cement Mill	Kiln	Coal Mill	Raw Material Mill	
1	Particulate Matter (PM) in mg/Nm ³ .	80.9	83.6	79.8	78.4	IS:11255 (Pt 1)
2	Flue Gas Temperature (°C) T _s	39.8	102.4	34.6	33.9	IS:11255 (Pt 3)
3	Flue Gas Velocity (m/s)	4.1	5.6	4.4	4.5	IS:11255 (Pt 3)
4	Ambient Temperature (T _a)	31.3	32.4	31.2	30.8	-
5	Height of H ₂ O Column in mm	1.39	2.21	1.68	1.75	-
6	Carbon Monoxide (CO) in ppm	-	132	-	-	IS:13270/GC
7	Carbon Dioxide (CO ₂) in %	-	8.7	-	-	IS:13270/GC
8	Oxygen (O ₂) in %	-	12.8	-	-	Orsat Apparatus
9	Sulfur Dioxide (SO ₂) in ppm	-	17	-	-	IS:11255 (Pt 2)
10	Oxides of Nitrogen (NO _x) in ppm	-	23	-	-	IS:11255 (Pt 7)

Sampling Instrument : Stack Monitoring Kit VSS-I & Flue Gas Analyzer (Quintox)

Permissible Standard for PM: 150 mg/ Nm³.

For Global Tech Enviro Experts Pvt. Ltd.


(Authorised Signatory)